

Submittal Data: TM12HTDI	12,000 BTU
Job Name	Location Date
Purchaser	Engineer
Submitted To	For Reference Approval Construction
Unit Designation	Schedule No.

#### GENERAL FEATURES

- -Floor Stand or Ceiling Mount
- -Quiet Operation -Multi-Speed Fan
- -4-way Discharge Air Flow
- -Swing Louvers
- -Remote Control Lockout
- -Wireless Remote Controllers
- -XK-19 Wired and Wireless Remote Controllers
- -Limited 5 yr. Parts Warranty



# System Ratings Cooling\* Rated Capacity 11,900 BTU/H

### Heating\*

Rated Capacity 13,100 BTU/H

## Sound Pressure (Hi/Lo)\*\*

Cooling 40/36 dbA Heating 40/36 dbA

#### Air Flow (min/max)

Indoor Fan 265/383 CFM

Physica	l Specifications

Unit Dimensions (LxHxD) 48.0 x 27.5 x 8.9 -in

Weight (Net/Shipping) 88/110 LBS

Drain Size (OD) 0.67-in 17-mm

#### **Electrical Ratings**

Fan Motor	
Output Power	55 W
FLA	0.28 A

#### Power Supply

Normal Operational Voltage

208/230 V, 1 Phase, 60 Hz

Voltage Range

187 - 253 V

MCA

1.0 A

Interconnecting Cable Wire Size

14-4 AWG

## Refrigerant Piping Data

Refrigerant Type R410A

Gas Pipe Size (OD) 3/8-in

Liquid Pipe Size (OD) 1/4-in

Connection Method Flared

Test conditions are based on AHRI 210/240.

\*Sound Power ratings are per AHRI 270 and AHRI 350








# 12,000 BTUH MODEL

Model # 12,000 BTUH 230V




**Dimensions** 


(mm)
(inches)


Α	В	С	D	Н	Н
1220	225	1158	280	700	700
48.0	8.9	45.6	11.0	27.6	27.6


Note: Size refrigerant lines based on evaporator port sizes.

# **MINIMUM CLEARANCE**









#### Notes:

- 1. Recommended Interconnecting Cable Type Stranded Bare Copper Conductors THHN 600V Unshielded Wire
- 2. Power wiring cable size must comply with applicable national and local codes.
- 3. Test conditions are based on AHRI 210/240.